


NOTES:

1. ONE PIER TO BE INSTALLED BEHIND BELL ON EACH JOINT OF DUCTILE IRON PIPE SUSPENDED IN AIR.
2. ALL PIERS OVER 3' IN HEIGHT SHALL BE REINFORCED WITH #4 BARS 12" O.C.
3. CONCRETE SHALL BE 3,000 PSI (CLASS A) CONCRETE.



CITY OF TYLER
STANDARD DETAIL

CONCRETE PIER

APPROVED: *Asa Crum*
UTILITIES ENGINEER
REVISION DATE: 8/2/11