


NOTES:

1. MATERIAL USED FOR BEDDING, HAUNCHING, INITIAL BACKFILL AND COVER SHALL ALL BE THE SAME MATERIAL AND SHALL BE IN ACCORDANCE WITH EMBEDMENT SPECIFICATION IN THE CITY OF TYLER STANDARD SPECIFICATION FOR HDPE PIPE.



CITY OF TYLER
STANDARD DETAIL

**TRENCH CROSS-SECTION
FOR HDPE PIPE**

APPROVED: *Ch. D. [Signature]*
CITY ENGINEER

REVISION DATE: 8/2/11