


NOTES:

1. TYPE K PIPE TO BE HELD LOW TO BEYOND PROPOSED CURB WITH A GRADUAL BEND TO WITHIN 12" OF FINISHED GRADE.
2. EACH SERVICE LINE SHALL BE PERMANENTLY MARKED WITH A "W" ON THE CURB WHERE THE SERVICE LINE CROSSES THE CURB.
3. METER STOPS TO REMAIN UNCOVERED UNTIL GPS COORDINATES ARE OBTAINED FOR END OF SERVICE.
4. T-POST, PLASTIC PIPE, OR SOME OTHER SEMI-PERMANENT MARKER, PAINTED BLUE, TO BE PLACED AT END OF SERVICE LINE UNTIL METER AND BOX CAN BE INSTALLED.
5. ALL FITTINGS ARE REQUIRED TO BE "NO LEAD".



CITY OF TYLER
STANDARD DETAIL

**WATER SERVICE
INSTALLATION**

APPROVED: *Rick Crum*
UTILITIES ENGINEER

REVISION DATE: 11/3/17