

City of Tyler
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 1
January 1, 2018 through March 31, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
1/5/2018	5:19 PM	1/5/2018	7:19 PM	8393 Garrett	T0000544	Contained in Street	60	0	Manhole	Grease & Debris	none	no	Manhole overflowed about 60 gals of sewer. Contained in street. Disinfected area and washed down with about 400 gals of fresh water. Returned about 300 gals of sewer and water back into system	1/6/18: Cabled main; 1/8/18: Camera'ed main; 1/9/18: Washed main.	no
1/5/2018	5:53 PM	1/5/2018	9:15 PM	N. Virginia & E. Line	T0005615	Contained in Street	75	0	Manhole	Grease & Roots	none	no	Manhole overflowed about 75 gals of sewer. Cleaned up, disinfected area and washed down with about 100 gals of fresh water. Unable to retrieve any of the spillage.	1/6/18: Cabled main; 1/9/18: Washed main; 1/10/18: Camera'ed main.	no
1/6/2018	3:12 PM	1/6/2018	6:15 PM	3133 Vineyard	T0002396	Storm Drain inlet	183	0	Manhole	Debris	none	no	Manhole overflowed about 183 gals of sewer in to storm drain inlet. Disinfected area and flushed 20,500 gals of fresh water from fire hydrant (FH). Unable to retrieve any of spill.	1/6/18: Cabled main; 1/8/18: Washed main; 1/10/18: Camera'ed main.	no
1/17/2018	3:57 PM	1/17/2018	4:30 PM	3307 Carver	T0010262	Contained on Ground	66	0	Clean-out	Debris	none	no	6" cleanout overflowed about 66 gals of sewer, was able to contain on the ground. Disinfected area. Unable to retrieve any of the spillage.	1/18/18: Camera'ed main; 1/19/18: Washed main; 1/30/18: Cabled main.	no
1/26/2018	8:29 PM	1/26/2018	9:50 PM	506 S. Vine	T0009095	Contained on Ground	31	31	Private clean-out	Grease & Roots	none	no	Public main stop. Private clean-out overflowed in yard about 31 gals of sewer. Disinfected area and washed down. Also had overflow in premise, about 50 gals. Helped owner cleanup areas and disinfect and mop.	1/27/18: Cabled main; 1/29/18: Washed main; 1/30/18: Camera'ed main.	no
1/30/2018	10:56 AM	1/30/2018	11:40 AM	5502 S. Broadway	T0004149	Trib M-3 to WMC	220	1,500	Manhole	Grease & Roots	none	no	Manhole overflowed about 220 gals of sewer into the creek. Disinfected area and flushed about 8000 gals of fresh water into creek. Set up down stream and vac'd about 1500 gals of sewer and creek water and returned to system.	1/30/18: Washed main; 2/1/18: Cabled and Camera'ed main.	no
2/2/2018	4:40 PM	2/2/2018	8:17 PM	1800 Pinecrest	T0005480	Trib B-18 to BFC	9,765	81,000	Pipe	Creek Erosion	none	no	Found 8 inch sewer main missing about 4 feet of pipe. Overflowed about 9,765 gals of sewer. Setup pumping downstream and pumped about 81,000 gals of sewer and creek water back in to system. Flushed about 64,500 gals of fresh water into creek. Made repairs.	2/2/18: Replaced section of pipe and cabled main; 2/3/18: Washed main; 2/6/18: Camera'ed main.	no
2/4/2018	2:07 PM	2/4/2018	3:39 PM	1405 Mockingbird	T0007129	Yard	10	0	Private Clean-out	Grease & Debris	none	no	Private cleanout overflowed about 10 gals. Disinfected and washed down area. Unable to retrieve any of the spillage.	2/4/18: Washed main; 2/5/18 Cabled and camera'ed main.	no
2/14/2018	12:01 PM	2/14/2018	12:53 PM	924 N. Parkdale	T0000397	Ground	104	0	Pipe	Broken Pipe	none	no	Walking sewer main outfall, found sewer leaking up from the ground in the backyard woods. Disinfected area with HTH and washed down with about 700 gals of fresh water. Unable to retrieve any of the overflow.	2/15/18: Cabled main; 2/16/18: Washed and camera'ed main.	no

City of Tyler
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 1
January 1, 2018 through March 31, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
2/20/2018	11:11 AM	2/20/2018	12:11 PM	4100 Troup Hwy	T0005583	Trib M-6 to WMC	1,500	5,000	Manhole	Grease	none	no	Manhole overflowed about 1,500 gals of sewer. Disinfected area and washed down with about 40,800 gals of fresh water. Set up down stream and vac'd about 5,000 gals of sewer and creek water back in to system.	2/20/18: Cabled and washed main; 2/23/18: Camera'ed main.	no
2/26/2018	6:06 PM	2/26/2018	6:57 PM	714 Shelley	T0003405	Contained In Street	13	15	Manhole	Debris	none	no	Disinfected area with HTH and washed down with about 35 gals of fresh water. Returned about 15 gals of sewer and water back in to system.	2/26/18: Cabled and camera'ed main; 2/27/18: Washed main.	no
2/23/2018	9:51 AM	2/23/2018	10:17 AM	1313 Pabst	T0013172	Trib D-1 to BFC	52	2,500	Manhole	Grease	none	no	About 52 gals of sewer overflowed in to the creek. Set up pumping down stream. Flushed about 4,200 gals of fresh water into creek and pumped about 2,500 gals of sewer and water back in to system. Disinfected area with HTH.	2/23/18: Cabled, washed and camera'ed main.	no
2/23/2018	9:14 AM	2/23/2018	10:00 AM	2602 Shenandoah	T0008884	Trib BF-22.3 to BFC	460	2,500	MH	Grease & Debris	none	no	About 460 gals of sewer overflowed from a manhole into the creek. Disinfected area around manhole and set up pumping downstream. Flushed about 16,000 gals of fresh water into creek and pumped about 2,500 gals of sewer & creek water back into system.	2/23/18: Washed main.	no
3/1/2018	8:37 AM	3/1/2018	8:50 AM	2714 Tenneha	T0008164	Contained on ground	1	5	Private clean-out	Roots & Debris	none	no	Public sewer stop caused private clean-out to overflow about 1 gal. Disinfected area around clean-out with HTH, washed down with about 5 gals of fresh water and cleaned up.	3/1/18: Cabled main; 3/2/18: Washed and camera'ed main.	no
3/5/2018	3:43 PM	3/5/2018	4:15 PM	2102 Boldt	T0008852	Contained in Yard	64	100	Private clean-out	Debris	none	no	Disinfected area with HTH and washed down with about 200 gals of fresh water. About 100 gals of sewer and water returned to system.	3/5/18: Cabled main; 3/6/18: Washed main; 3/8/18: Camera'ed main.	no
3/5/2018	11:03 AM	3/5/2018	11:23 AM	Beechwood & Harwood	T0004005	Trib C-3 to WMC	60	2000	MH	Roots & Debris	none	no	Disinfected area with HTH. Flushed creek with about 4000 gals of fresh water. Set up downstream and pumped about 2000 gals of sewer and creek water back in to system. Also had overflow in-premise report.	3/5/18: Cabled and washed main; 3/6/18: Camera'ed main.	no
3/7/2018	3:13 PM	3/7/2018	3:53 PM	6150 Rhones Quarter	T0000065	Contained on ground	800	800	Force Main	Contractor Damage	none	no	The mobile home park has a private collection system. We first believed it to be a private issue. They dug it up and found the force main. We made the repair. Disinfected the area and washed down with about 500 gals of fresh water. Private pumping contractor cleaned up the area and returned to our system.	N/A	no
3/9/2018	8:51 PM	3/9/2018	9:16 PM	1820 Don	T0004243	BFC Trib M-1	6	500	Private clean-out	Grease & Debris	none	no	About 6 gals of sewer overflowed into a flowing creek. Disinfected area and washed down with about 50 gals of fresh water. Set up downstream and vac'd about 500 gals of sewer & creek water back in to system.	3/9/18: Cabled, washed and camera'ed main.	no

City of Tyler
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 1
January 1, 2018 through March 31, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
3/16/2018	9:45 AM	3/16/2018	11:30 AM	725 Beth	T0009891	WMC Trib M2.2	525	2,100	Manhole	Grease & Debris	none	no	Manhole overflowed about 525 gals of sewer into a flowing creek. Disinfected area and washed down area. Flushed about 21,000 gals of fresh water into the creek. Set up downstream and pumped about 2,500 gals of sewer and creek water back into the system.	3/16/18: Cabled main; 3/17/18: Washed main; 3/19/18: Camera'ed main.	no
3/16/2018	12:56 PM	3/16/2018	1:07 PM	715 E. Line	T0004588	Street	44	200	Manhole	Debris	none	no	Manhole overflowed about 44 gals of sewer. Disinfected area and washed down with about 156 gals of fresh water. Vac'd up about 200 gals of sewer and fresh water. Returned to system.	3/17/18: Washed main; 3/19/18: Cabled and camera'ed main.	no
3/26/2018	9:56 AM	3/26/2018	10:16 AM	1811 Rickety	T0006138	WMC Trib M-6	200	1,000	Manhole	Grease	none	no	Manhole overflowed about 200 gals of sewer into flowing creek. Disinfected area around manhole and flushed about 4,000 gals of fresh water in to creek. We set up downstream and pumped about 1,000 gals of sewer and creek water back in to system.	3/26/18: Cabled main; 3/27/18: Washed and camera'ed main.	no
3/26/2018	6:15 PM	3/26/2018	7:10 PM	Grand Ave & Mimms	T0003026	BFC Trib 3.3	55	0	Manhole	Grease	none	no	Manhole overflowed about 55 gals into flowing creek. Disinfected area around manhole and flushed about 12,000 gals of fresh water in to creek. Could not retrieve any of the overflow.	3/27/18: Cabled, washed and camera'ed main.	no

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.


Scott Taylor, P.E., Managing Director of Utilities and Public Works


Date