

City of Tyler  
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 2  
April 1, 2018 through June 30, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
4/5/2018	11:15 AM	4/5/2018	3:00 PM	4085 Hogan	T0010137	IC Trib 1.2	6000	0	Lift Station	Broken Pipe	Yes	no	Plugged 10" sewer main. Setup by-pass pumping.	4/9/2018 cabled, washed and CCTVed main.	No
4/6/2018	8:06 AM	4/6/2018	12:25 PM	1601 Everglades	T0003985	Trib M-5 to WMC	3855	40000	MH	Grease	Yes	No	Arrived at location and followed creek to 4600 Paluxy. MH on the east side of Paluxy was overflowing. MH overflowing approximately 15 GPM flowing into flowing creek. Knocked stop off at 12:25 PM approximately 3,855 gallons of sewer into creek. Set up at 1511 Yosemite, opened two fire hydrants one at 4600 Paluxy and one at 1826 Sequoia. Opened at approximately 200 GPM per fire hydrant a total of 400 GPM cleaned up solids and sanitized area.	4/6/2018: pumped creek and washed main; 4/10/2018: cabled and CCTVed main.	No
4/4/2018	1:38 PM	4/4/2018	2:08 PM	Earl Campbell Pkwy	T0011053	Storm Drain inlet	30	1030	MH	Grease	No	no	Arrived at location, unit 607 already on site MH in the street was leaking approximately 1 GPM got the top off at 2:08 PM. Approximately 30 gallons of sewer contained in storm drain inlet box. Sanitized with HTH washed down with approximately 500 gallons of fresh water. Used vac truck to flush 1000 gallons of fresh water into the system.	4/6/2018: cabled main; 4/11/2018: washed main; 4/12/2018 CCTVed main.	No
4/21/2018	12:55 PM	4/21/2018	1:30 PM	3715 Wynnwood	T0000703	Trib C-1 to WMC	70	0	co	grease	no	no	C/O leaking 2 gpm into flowing creek. Came in at 12:55 pm relieved stop @ 1:30 pm. Approximately 70 gallons of sewer entering flowing creek. Disinfected & cleaned up and flushed 12,500 gallons of fresh water. Raining outside so sewer was unretrievable. Ran MH @ 3815 Wynnwood north 30ft to relieve stop. This was a grease stop.	New manhole installed. 4/21/2018: cabled main; 4/23/2018: washed and CCTVed main.	No
4/23/2018	12:18 PM	4/23/2018	12:21 PM	2695 ssw loop 323	T001148	contained in yard	2	52	MH	grease	no	no	Arrived at location and manhole was seeping 2 gpm. We ran 250 feet and relieved stop at 80 feet. We disinfected around manhole. Flushed 50 gallons of water from vac truck and vac'ed up 52 gallons of sewer contained in yard and returned it back into sewer main.	Repair of sewer main. 4/24/2018: cleaned and CCTVed main.	No
4/24/2018	8:00 PM	4/24/2018	9:00 PM	720 Rosedale	T0002972	Trib D-1 to BFC	30	18,030	MH	Debris	no	no	MH @ 720 Rosedale overflowing approximately 0.5 GPM. Hit stop at 420 ft relieved stop at 430 ft. Approximately 30 gallons of sewer flowed into storm drain and into creek, called crew to pump creek. Sanitized area with HTH and 250 gallons of fresh water. Opened the fire hydrant at 1118 E. Gentry at approximately 300 GPM. 18,000 gallons of fresh water flushed back into creek.	4/25/2018: cabled, cleaned and CCTVed main.	No

City of Tyler  
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 2  
April 1, 2018 through June 30, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
4/27/2018	1:03 PM	4/27/2018	1:58 PM	S. Palace & Connally	T0007092	Storm Drain inlet	14	513	MH	Debris	No	No	Noticed manhole leaking approximately 5 gpm at Connally and went to downstream manhole at South Palace. Ran west 150 feet hit stop at 140 feet. Relieved stop at 145 feet. Approximately 13.5 gallons of sewer contained in the curb and gutter. Vac'ed up sewer from curb, sanitized with HTH. Opened fire hydrant and flushed approx. 500 gallons of fresh water.	4/27/2018: cabled, cleaned and CCTVed main.	No
4/27/2018	12:06 PM	4/27/2018	1:16 PM	Connally & Old Noonday	T0008770	Storm Drain inlet	35	535	MH	Debris	No	No	Arrived at location saw the manhole at Connally and South Glenwood was leaking approximately 0.5 gpm. Went to downstream manhole and 1016 Rusk. Ran south 353 feet hit stop at 300 feet relieved stop at 320 feet. 35 gallons of sewer contained in storm drain. Opened fire hydrant flushed and vac'ed up 535 gallons of water & sewer and sanitized with HTH. Washed down around manhole.	4/27/2018: cabled, cleaned and CCTVed main.	No
5/11/2018	3:36 PM	5/11/2018	6:00 PM	2695 SSW loop 323	T0003461	Indian Creek	2880	18000	GM	Break	No	No	Followed creek upstream following the creek and found where a part of the 10" main had come apart. Discharging sewer approx. 20gpm, called unit 607 to get a crew to come and repair main. Approximately 2880 gallons of sewer in flowing creek. Crew set up down stream at Cascade Dr. to pump creek. Opened fire hydrant upstream beside SSW Loop 323. Flushed approx 12,000 gallons of fresh water back into creek. Sanitized creek with HTH and poured dye for a visual to let the crew know when fresh water had arrived to them. Crew pumped approximately 18,000 gallons of sewer, creek water and fresh water pumped back into sewer system.	5/11/2018: repaired main; 5/12/2018: washed main; 5/14/2018 CCTVed main; 5/16/2018: cabled main.	No
5/23/2018	8:09 AM	5/23/2018	11:43 AM	2714 Mcdonald Rd	T0003850	Trib 8F-22 to BFC	2,560	10,000	MH	Grease	No	No	Knocked stop off @ 11:43 AM. MH @ Loop 323 & Mcdonald Rd was leaking approximately 20gpm. The stop was in the invert of mh. Approximately 2560 Gal of sewer entered flowing creek. Flushed with 15,450 gal of fresh water into creek. Vac'ed & retrieved 10,000 gal of fresh water, sewer & creek water mix from creek and pumped back into sewer system.	5/24/2018: washed and CCTVed main; 5/25/2018 cabled main.	No
5/30/2018	8:28 AM	5/30/2018	11:28 AM	Rickety & Sybil	T0002711	Trib M-6 to WMC	1800	3000	MH	Grease	no	no	Found manhole overflowing 10 gpm resulting in 1800 gallons in creek. We disinfected around manhole and pumped creek.	5/30/2018: cabled, washed and CCTVed main.	No

City of Tyler  
Consent Decree, DOJ No. 90-5-1-1-09767

Quarterly Report - 2018 Quarter 2  
April 1, 2018 through June 30, 2018

Start Date	Start Time	End Date	End Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Impact on Human Health and Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments / Response to SSO	Follow-up Actions Taken	Public Notification Made?
6/5/2018	9:40 AM	6/5/2018	10:48 AM	4053 troupe HWY	T0005585	Trib M-6 to WMC	1360	54,360	mh	Broken Pipe	no	no	Found manhole at 2504 Troup Hwy. Ran east 5 feet and knocked off stop. 1360 gallons of sewer in creek. Set up to vac out sewer from creek. Opened fire hydrant at 3900 Troup Hwy at 200 gpm. Sanitized creek with HTH and added green dye for visual. Opened hydrant at 11:30 am, ran fresh water back into creek. Closed hydrant at 3:40 pm at 200 gpm. 50,000 gallons of fresh water into creek. Vac'ed out 6 loads of sewer, water and creek water mix for a total of 15,000 gallons and put back into the system.	6/6/2018: repaired and cabled main; 6/7/2018: washed main; 6/8/2018: CCTVed main.	No
6/17/2018	5:12 PM	6/17/2018	5:45 PM	Hwy 14 & CR 328	Lift Station	N/A	33	33	Lift Station	Lift Station	No	No	Arrived at above location assist with lift station it was leaking 1 gpm for a total of 33 gallons of sewer contained in yard it was disinfected, washed down and returned to system.	Cleaned and contacted lift station technician	No
6/22/2018	4:11 PM	6/22/2018	6:00 PM	Broadway & 1st	T0008991	N/A	450	5000	MH	Grease	No	No	Arrived at location manhole overflowing approximately 490 gal of sewer. Entered storm drain and contained in storm drain box. Ran about 710 ft to next MH to knock off stop. Wash down street and disinfected with HTH and 2000 gal fresh water. Vac'ed out storm drain box and retrieved sewer & fresh water, approximately 5000gal and returned to system.	6/25/2018: cabled and washed main; 6/26/2018: CCTVed main.	No

**CERTIFICATION:**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

  
 Scott Taylor, P.E., Managing Director of Utilities and Public Works
 
  
 Date